

MODEL:		TYPE
PROJECT:		
PREPARED BY:	DATE:	

SERIES SPECIFICATIONS

Passive Infrared Vacancy Sensor w/ manual override switch, 15A 120V, Single Pole, Auto Off

Manual On-Automatic Off
Automatic off after time delay expires with manual "off" option
Adjustable sensitivity settings
Complies with California Title 24
Decorator Wallplate Included





CONSTRUCTION

Color Mounting Operation Temperature Ivory Wall 32°F to 131°F (0°C to 55°C)

Sensor TechnologyTime DelayLight LevelPassive Infrared15 Seconds to 30 Minutes30 Lux-Daylight

Coverage 1 Coverage 2

150, 450 square feet 180, 500 square feet

ELECTRICAL SPECIFICATIONS

Voltage Poles Hertz 120 V AC Single 60 Hz

Horsepower Time Delay Load Rating 1

1/8 HP 15 Seconds to 30 Minutes Incandescent lamp: 500 Watt

Load Rating 2 Load Rating 3
Flourescent lamp: 500 VA Motor Load: 1/8HP

APPLICATION AND PERFORMANCE SPECIFICATION INFORMATION IS SUBJECT TO CHANGE WITHOUT NOTIFICATION



MODEL:		TYPE
PROJECT:		
PREPARED BY:	DATE:	

CERTIFICATIONS/WARRANTY

Listing cULus Listed

Warranty

Guaranteed for one year from the purchase date of the product, against mechanical defects in manufacturing.

ORDERING INFORMATION

Part Number: VCSSVW15-IV

Box Qty: 10 Weight (Lbs): 0.331

Carton Qty.: 40 IMS Code: 0277-7103

